# BALTIMORE COUNTY, MARYLAND DEPARTMENT OF PUBLIC WORKS AND TRANSPORTATION DIVISION OF CONSTRUCTION CONTRACTS ADMINISTRATION 111 WEST CHESAPEAKE AVENUE TOWSON, MARYLAND 21204



Contract No. 17031 SX0
Herring Run Sewershed Structural Sewer Rehabilitation – Phase II
Job Order No. 231-201-0077-7235
Workday No. 010777235
Towson – District 9c5,6

# **ADDENDUM NO. 3**

**DATE:** 7/18/2025

Contact: Barb Wentworth, 410-887-3531, bwentworth@baltimorecountymd.gov

# To All Bidders

This addendum is hereby made a part of the Proposal and the Special Provisions, and is hereby incorporated into the Contract. Should this addendum conflict with any portion of the Special Provisions, the Proposal, or any prior addenda, this addendum shall supersede and control.

Please note the attached changes, corrections, and/or information in connection with the contract and submit bids and be otherwise governed accordingly.

### For Your Information

Attachments - 1

Please sign below acknowledging receipt of this addendum and return with your bid.

Company Name	Signature

# HERRING RUN SEWERSHED STRUCTURAL SEWER REHABILITATION — PHASE II CONTRACT NO. 17031 SX0 JOB ORDER NO. 231-201-0077-7235 PRE-BID QUESTIONS AND ANSWERS

### QUESTION 1:

- Can you clarify if the use of steam cure CIPP is allowed on this project? The specification states that steam cure is allowed, but the prebid meeting minutes distributed with addendum 2 mentions that steam cure is not allowed. Please clarify.
- Additionally, the prebid meeting minutes state that the curing process shall be water cure, but the specifications only mention steam cure and UV cure as allowable. Please clarify which curing methods are and are not allowed on this project.

### ANSWER 1:

Steam cure and UV cure are allowable methods, per the specifications. Water cure is allowable upon request where the contractor deems it necessary; however, there will be no additional compensation for water cure.

NO FURTHER QUESTIONS WERE RECEIVED.