

BALTIMORE COUNTY, MARYLAND
DEPARTMENT OF PUBLIC WORKS AND TRANSPORTATION
DIVISION OF CONSTRUCTION CONTRACTS ADMINISTRATION
111 WEST CHESAPEAKE AVENUE
TOWSON, MARYLAND 21204



Contract No. 23137 GX0
Project No's.
100362239
Fort Howard Park Waterline Replacement –
9500 North Point Road, Fort Howard, Maryland 21052
Fort Howard – District 15c7

ADDENDUM NO. 3

DATE: 9/24/2025

Contact: Anthony Crews, 410-887-3531, tcrews@baltimorecountymd.gov

To All Bidders

This addendum is hereby made a part of the Proposal and the Special Provisions, and is hereby incorporated into the Contract. Should this addendum conflict with any portion of the Special Provisions, the Proposal, or any prior addenda, this addendum shall supersede and control.

Please note the attached changes, corrections, and/or information in connection with the contract and submit bids and be otherwise governed accordingly.

For Your Information

Attached is a question and answer.

Attachments – 1

Please sign below acknowledging receipt of this addendum and return with your bid.

Company Name

Signature



Baltimore County Office of Budget & Finance Property Management Division

Addendum #3

Project: Fort Howard Park – Water line replacement project

Contract No. 23137 GX0

Date of Addendum: 9/24/2025

This addendum #3 includes response to a question received via email.

Question: We need to know if the existing material is suitable for backfilling the ditch. If not, how do we get paid to bring in borrow material? The county usually has a contingent item for borrow and test pits and other miscellaneous items.

Response: Based on our field visit, visual inspection, and past investigation for buried ordinances, the excavated material is suitable for backfill and the contractor can utilize the excavated material for backfill in consultation with the field inspector and/or designer.
