

**BALTIMORE COUNTY, MARYLAND
DEPARTMENT OF PUBLIC WORKS & TRANSPORTATION
DIVISION OF CONSTRUCTION CONTRACTS ADMINISTRATION
111 WEST CHESAPEAKE AVENUE
TOWSON, MARYLAND 21204**



Contract No. 24024 GX0
Pittsfield Road Stream Restoration at
Green Valley, Owings Mills, MD. 21117
Owings Mills – District 3c2
Workday No.
Proj-10001417, 214000351, 10000198

ADDENDUM NO. 1

DATE: 4/1/2025

Contact: Anthony Crews, 410-887-3531, tcrews@baltimorecountymd.gov

To All Bidders

This addendum is hereby made a part of the Proposal and the Special Provisions, and is hereby incorporated into the Contract. Should this addendum conflict with any portion of the Special Provisions, the Proposal, or any prior addenda, this addendum shall supersede and control.

Please note the attached changes, corrections, and/or information in connection with the contract and submit bids and be otherwise governed accordingly.

For Your Information

See attached question and answer.

Attachments – 1

**PLEASE SIGN BELOW ACKNOWLEDGING RECEIPT OF THIS
ADDENDUM AND RETURN WITH YOUR BID.**

Company Name

Signature

Q: Will the CADD file or a PDF file with the vector information be made available? We will need this to calculate the amount of Class 5 excavation.

Answer: Due to concerns with data security and contractual requirements, no PDF file with vector information will be provided. Baltimore County EPS and DPWT will only provide CADD files to the winning bidder.

Cut/Fill breakdown per reach based on existing to proposed surface (not accounting for any subgrade excavation or imported material):

REACH	CUT (CY)	FILL (CY)
Greenshire	1063	657
SD-1	1	2
SD-2	2	6
Mainstem US of Pittsfield Rd	358	824
SD-3	1	17
SD-4	2	14
Wellhaven	168	97
SD-5	26	43
SD-6	16	1
Mainstem DS of Pittsfield Rd	688	1973
SD-7	2	14
SD-8	5	9
Green Valley	41	8
Hartley including SD-10 and SD-11	299	226
SD-9	17	0
TOTAL	2691	3892