BALTIMORE COUNTY, MARYLAND DEPARTMENT OF PUBLIC WORKS AND TRANSPORTATION DIVISION OF CONSTRUCTION CONTRACTS ADMINISTRATION 111 WEST CHESAPEAKE AVENUE TOWSON, MARYLAND 21204



Contract No. 24146 PO0 Project No. 10000216 North Point Library HVAC Renovation -1716 Merritt Boulevard, Dundalk, Maryland 21222 Dundalk – District 12c7

ADDENDUM NO. 3

DATE: 6/20/2025

Contact: Anthony Crews, 410-887-3531, tcrews@baltimorecountymd.gov

To All Bidders

This addendum is hereby made a part of the Proposal and the Special Provisions, and is hereby incorporated into the Contract. Should this addendum conflict with any portion of the Special Provisions, the Proposal, or any prior addenda, this addendum shall supersede and control.

Please note the attached changes, corrections, and/or information in connection with the contract and submit bids and be otherwise governed accordingly.

For Your Information

Attached are questions and answers. Along with the list of attendees from site visit.

Attachments – 3

Please sign below acknowledging receipt of this addendum and return with your bid.

Company Name

Signature

RFI # 2 Question and answer below each RFI

Popcorn plastered bulkhead in phase 3 will need to be removed to remove some existing ductwork. Is this material asbestos?

If County has no information prior, should material resembling asbestos-containing materials be encountered during execution of work, immediately notify Counties field representative for instructions before proceeding with work.

Does this bulkhead need to be patched to match existing finish? Yes.

ATTENDANCE SHEET PLEASE PRINT

Project Name: North Point Library

Date Held: 6/9/25

556.35

| | | | 1 | |
|-----------------|----------------------|---------------|----------|---|
| Name | Company | Phone # | Initials | Email Address |
| Brook Behner | Strayer contracting | 717-424-1875 | +5 | Brook.behner@strayercontracting.com |
| Tom Lamb | Key systems | 2 | | tlamb@keysystemselectric.com |
| Paul Purdham | M&M | 321,637.6065 | PDP | ppurdham@mandmwelding.com |
| Teresa Chandler | Towson Mechanical | - | | tchandler@towsonmechanical.com |
| Rob Chilcoat | Chilmar corporation | 443-250-1429 | Rv | RobC@chilmar.com |
| N John Rizzotti | Albireo Energy | 4/4364/0-5776 | JMR | jrizzotti@albireoenergy.com |
| N Bekim Jusufi | Hot&Cold Corporation | 240 660 -1629 | | bekimjusufi@hotcoldcorporation.com |
| Red . | | 24 | | |
| Allo (250/bus | KS CONSTRUCTION | 443 635 3852 | - | Konto KS CONSTRUCTION @ GMOSI/ . CC |
| jtephanis Roans | Roanes Rigging | 410-325-7606 | SZ | francs rigging a |
| PETER PUSZCZ | HENRY ADAMS | 410 336 840-7 | PTP | PUSCOR HENRY GOAMS. COM |
| RYAN BAUER | BAUER MECH | 443-987-2336 | VB | RBAVER PBAUERMECH.CO Contract No.24146 Addendum No.3 June 20. 2025 |
| Eric Mahala | FCR Enterprises | 443-877-0573 | CM | emahale Oferenterprises com |

Key Systems TL TLambe Keysystemselectic, 443 497 0327 TomLamb

Barrie Milling

Contract No.24146 PO0 Addendum No.3 June 20, 2025

Sec. Sec.

1 14 T 15 14