

**BALTIMORE COUNTY, MARYLAND  
DEPARTMENT OF PUBLIC WORKS AND TRANSPORTATION  
DIVISION OF CONSTRUCTION CONTRACTS ADMINISTRATION  
111 WEST CHESAPEAKE AVENUE  
TOWSON, MARYLAND 21204**



Contract No. 25034 PF0 Re-Bid  
Project No's. Proj-200540012  
Fullerton Fire Station #8 Ladies Renovation & Addition -  
4401 Fitch Avenue, Nottingham, Maryland 21236  
Nottingham – District 14c5

**ADDENDUM NO.6**

**DATE:** 6/10/2025

**Contact:** Anthony Crews, 410-887-3531, [tcrews@baltimorecountymd.gov](mailto:tcrews@baltimorecountymd.gov)

**To All Bidders**

This addendum is hereby made a part of the Proposal and the Special Provisions, and is hereby incorporated into the Contract. Should this addendum conflict with any portion of the Special Provisions, the Proposal, or any prior addenda, this addendum shall supersede and control.

Please note the attached changes, corrections, and/or information in connection with the contract and submit bids and be otherwise governed accordingly.

**For Your Information**

Attached are questions and answers. See reference to contractor parking.

Attachments – 2

**Please sign below acknowledging receipt of this addendum and return with your bid.**

\_\_\_\_\_  
**Company Name**

\_\_\_\_\_  
**Signature**



## ADDENDUM 06

**PROJECT:** Fullerton Fire Station #8 – Renovation  
& Addition

**MWS PROJECT NO:** 20-120

**ADDRESS:** 4401 Fitch Avenue

**CONTRACT NO.** 25034 PFO  
Re-Bid


Nottingham, Maryland, 21236

**ISSUE DATE:** June 9, 2025

The following changes shall be incorporated into the work in accordance with all general requirements as if incorporated in the original documents.

### GENERAL CHANGES:

1. Baltimore County Transportation has agreed to cover existing NO PARKING street signs for duration of project which will add approximately 15 available spaces on the east side of Fitch Ln adjacent to the Fire Dept. for contractor parking. Also, BC is looking into approving temporary use of Fitch Ln for a superintendent trailer and/or dumpster. See image below for highlighted area for use of contractor parking:



## CHANGES TO DRAWINGS:

## CHANGES TO SPECIFICATIONS:

## BIDDER QUESTIONS & RESPONSES:

- 1.) **QUESTION:** Can you please provide the electrical specification requirements for the Temporary Modular Trailers?
  - a. Voltage?:
  - b. AMPS?
  - c. Panels specifications?
  - d. Data/Communications?
  - e. Fire Alarm?
2. **RESPONSE:** Per AD100 Contractor and applicable sub-contractors are responsible for determining and coordinating the installation of the temporary facilities. Contractor responsibility include but are not limited to any and all necessary electrical power, water, sanitary, natural gas, temporary foundations, fire alarm, sprinkler systems, associated walkways connecting facilities to the existing station and all necessary permitting required to complete the installation of the temporary living facilities in a code compliant manner. For data, communications and fire station alerting system within the temporary facilities, Contractor to provide two, 2" conduits to run from existing basement/server rack, overhead to Trailer 3. Contractor to make final coordination of conduit routing with final placement of temporary facilities and County OIT prior to final installation. County to provide data and Computer Aided Dispatch System to temporary trailers, as indicated in Addendum #4.
- 2.) **QUESTION:** Will the Temporary Service come from the BGE service poles?  
**RESPONSE:** Contractor is responsible for establishing a dedicated temporary electrical service via BGE from the service pole. See Addendum #4 for additional information.

## ATTACHMENTS:

# END OF ADDENDUM #6